
From: LeadInventory DEQ
Sent: Tuesday, October 8, 2024 9:40 AM
To:
Subject: Approved Non-Lead Form - Kearns Improvement District, UTAH

Dear Kearns Improvement District,

Thank you for submitting the Non-Lead Form. Your Non-Lead Form has been reviewed and based on the supporting documentation you included, it has been approved.

What this means for your system:

This Non-Lead Form will be used in place of the completed Initial Inventory Template that is due Oct. 16, 2024. You do need to keep a service line inventory on file for your own purposes as the division may request it at a later date.

Non-lead systems must fulfill the public accessibility requirement by providing a public statement they have no lead service lines or galvanized service lines requiring replacement and a general description of how they made that determination.

Keep in mind that additional inventory requirements are being considered in the [proposed EPA Lead and Copper Rule Improvements \(LCRI\)](#). A requirement that is being proposed in EPA's LCRI that may affect Kearns Improvement District water systems inventory is updating the inventory to include all service line connectors in an effort to identify and replace Lead connectors.

Note: In the [proposed EPA Lead and Copper Rule Improvements \(LCRI\)](#), systems must validate the accuracy of a pool of service lines that were determined to be non-lead through any method other than record reviews and 2-point field verification (utility side and customer side) no later than ten years after the final LCRI is published. Service lines that were determined to be non-lead by using the 1970 cutoff date, minimum service line material verification (MSLMV) process/statistical modeling or by using anecdotal reports may require future validation through this proposed requirement.

Thank you,

--



DDW Lead Team

Lead Inventory | Division of Drinking Water

M: (801) 536-4200

P: (385) 501-9128

195 N. 1950 W.

Salt Lake City, UT 84116